

WATER QUALITY MONITORING & SURVEILLANCE PROGRAMME
RAJGANJ WELFARE ORGANISATION SUB-DISTRICT WATER TESTING LABORATORY
P.H.E.DTE.

TEST DATE- 08.05.2023

COMPLETION DATE-09.05.2023

		ACCEPTABLE LIMIT AS PART OF IS 10500:2012 →	6.5- 8.5	500mg/lit	1 NTU	0.3 mg/lit	0.1 mg/lit	0 CFU/100ml	200 mg/lit		
		PERMISSIBLE LIMIT AS PART OF IS 10500:2012→	6.5- 8.5	2000mg/lit	5 NTU	1 mg/lit	0.3 mg/lit	0 CFU/100ml	600 mg/lit		
Sample No.	Type of Source	Location Description	pH	TDS	Turbidity	Iron	Manganese	Total Coliform	Faecal Coliform	Hardness	Conductivity
1.	Bore Water	Holy Cross School, Balaigach, P.O. Manuaganj, P.S. Rajganj, Dist. Jalpaiguri, Pin. 735135, West Bengal	6.75	37	2.98	0.39	0.06	0	0	28	61.8



Sayed Rishmas
12.05.2023
Chemist / Bacteriologist
Rajganj Water Testing Lab
Rajganj Welfare Organisation
P.O.- Rajganj, Dt.- Jalpaiguri